Protection and Control of Modern Power Systems

CORRECTION

Open Access

Publisher Correction: Reactive power optimization of a distribution network with high-penetration of wind and solar renewable energy and electric vehicles

Biao Xu[1], Guiyuan Zhang[1], Ke Li[1*], Bing Li[1], Hongyuan Chi[2], Yao Yao[1] and Zhun Fan[1]

Correction: Protection and Control of Modern Power Systems (2022) 7:51
https://doi.org/10.1186/s41601-022-00271-w

Following the publication of original article [1], the below duplicate content mistakenly appeared in two other places due to a typesetting error.

where O means the set of operating generation units at the cth control interval, and $R_j(c)$ is the downward ramp rate of the jth generation unit. $\Delta P_j^{min}(c)$ represents the minimum active output of the jth generation unit in the cth control interval, and $P_D(c+1)$ means the total active power demand of the power grid at the $(c+1)$th interval.

The original article [1] has been corrected. The publisher apologizes for the inconvenience caused.

Published online: 15 May 2023

Reference

1. Xu, B., et al. (2022). Reactive power optimization of a distribution network with high-penetration of wind and solar renewable energy and electric vehicles. *Protection and Control of Modern Power Systems, 7*, 51.

The original article can be found online at https://doi.org/10.1186/s41601-022-00271-w.

*Correspondence:
Ke Li
ericlee@stu.edu.cn
[1] Shantou University, Shantou, China
[2] The AI Application and Innovation Center of China Mobile Communications Group Guangdong Co., Ltd., Shantou, China